



Product	AC/DC switching power supply
Applicant	Bel Fuse Inc. 206 Van Vorst St. Jersey City, NJ 07302 USA
Manufacturer	Bel Fuse Inc. 206 Van Vorst St. Jersey City, NJ 07302 USA
Factory	BPS Asia Pacific Electronics (Shenzhen) Co., Ltd. Building# 6, Nanming Road, Gongming Town, Huahong Xintong Industrial Park, Guangming District, Shenzhen 518108 China
Ratings	Input: 1.8 A, 100-240 Vac, 50/60 Hz
Trade mark	
Model / Type Ref.	MPB125-xxxx Series
Principal characteristics	Output ratings see the test report. The followed by suffix R or G or X or combinations of different suffixes), where R denotes stand-by and remote on/off circuitry, G denotes ROHS version and X denotes a series of alphanumeric characters indicating non-safety critical options, more information see the test report.
A sample of the product was tested and found to be in conformity with	ITAV EN IEC 62368-1:2020;A11
Validity	This certificate documents conformity with the standards shown, and also applies as license for use of Nemkos name and certification mark. The certificate and license is valid as long as the applicable conditions are complied with, and provided that any changes to the product are notified to Nemko for acceptance prior to implementation. New standards or amendments to the standards may imply that the product design must be updated and/or that re-testing and re-certification is necessary.
Additional information	Compliance with requirements regarding building-in, protection against electric shock and Electromagnetic Compatibility (EMC) must be checked when the equipment is built-in a completed product or forms a part of a complete system.
Additional model(s)	No additional models

Date of issue 14-08-2020



Juan Z. Saussey
Certification Department

Nemko AS

Philip Pedersens vei 11, 1366 Lysaker, Norway
TEL +47 22 96 03 30 EMAIL info@nemko.com
ENTERPRISE NUMBER NO974404532