Zertifikat
mit überwachter Konformität

Certificate
of surveyed conformity

Zertifikat Nr. ***Certificate No.***
J 50691066

Blatt ***Sheet***
0001

Ihr Zeichen *Client Reference*	**Unser Zeichen** *Our Reference*	**Ausstellungsdatum**	*Date of Issue*
	05-xieb-CN24UV6F 002	03.09.2025	*(day/mo/yr)*

Genehmigungsinhaber ***License Holder***
Bel Fuse Ltd.
8/F,Luk Hop Industrial Building
8 Luk Hop Street,San Po Kong
Kowloon
Hong Kong

Fertigungsstätte ***Manufacturing Plant***
040-0002178682

Prüfzeichen ***Test Mark***

TÜVRheinland CERTIFIED
Safety
Regular
Production
Surveillance
www.tuv.com
ID 1111305854

Geprüft nach ***Tested acc. to***
EN 60127-1:2006+A1+A2
EN 60127-2:2014+A1

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

(Cartridge Fuse-links)

Type Designation	: 0652C 0652P	15
Trademark	: bel	
Rated Voltage(Un)	: 1)&2)&3) AC 250V, 4) AC 125V/250V/350V	
Rated Current(In)	: 1) 100mA, 125mA, 160mA, 200mA, 250mA, 315mA, 400mA, 500mA, 630mA, 800mA, 1A	
	2) 1.25A, 1.6A, 2A, 2.5A, 3.15A	
	3) 4A, 5A, 6.3A, 8A, 10A,	
	4) 12A, 12.5A, 15A, 16A, 20A	
T/I Characteristic	: T	
Rated Breaking Capacity	: 1) 35A at AC 250V,	
	2) 100A at AC 250V	
	3) 200A at AC 250V	
	4) 750A at AC 125V, 600A at AC 250V	
	300A at AC 350V	
Dimensions	: 5mmx20mm, with or without pigtail	

15

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde.
Das Produkt entspricht den o.g. Anforderungen, die Herstellung wird überwacht.
This certificate is based on our Testing and Certification Regulation. The product fulfills above mentioned requirements, the production is subject to surveillance.

TÜV Rheinland LGA Products GmbH Zertifizierungsstelle

Zertifizierungsstelle

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg
http://www.tuv.com/safety E-mail: markcheck@tuv.com
Fax: +49 221 806-3935

Sarah Chen

Sarah Chen

10/020 d 04.08 ® TÜV, TUEV and TUV are registered trademarks. Utilisation and application requires prior approval.