Ref. Certif. No.

CA/39559/CSA

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	AC-DC Converter
Name and address of the applicant	Bel Fuse Inc. 300 Executive Drive, Suite 300, West Orange, NJ 07052, USA
Name and address of the manufacturer	Bel Fuse Inc. 300 Executive Drive, Suite 300, West Orange, NJ 07052, USA
Name and address of the factory Note: *When more than one factory, please report on page 2*	Bel Power Solutions s.r.o Areal ZTS 924 Dubnica nad Vahom 01841 SLOVAKIA ☐ Additional Information on page 2
Ratings and principal characteristics	AC INPUT (WYE, without neutral): 3 Phase 230-277 / 400-480Vac, 50/60Hz, 3W + PE, 9 - 7 A DC OUTPUT: 39 – 57 Vdc, Max. 105 A, Maximum output power 5000 W
Trademark / Brand (if any)	bel POWER SOLUTIONS & PROTECTION a bel group or bel
Customer's Testing Facility (CTF) Stage used	CTF Stage 3
Model / Type Ref.	TLP5000-1048, maybe followed by alpha-numeric characters denoting non-safety critical options.
Additional information (if necessary may also be reported on page 2)	Refer to CB Test Report for National Deviations ☐ Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 62368-1:2023
As shown in the Test Report Ref. No. which forms part of this Certificate	CB 170351 - 80304486

This CB Test Certificate is issued by the National Certification Body

CSA GROUP™

CSA Group
178 Rexdale Boulevard
Toronto, ON M9W 1R3 Canada

Date: 2026-06-16

Signature: Daniel Duguay