



中国国家强制性产品认证证书

证书编号: 2016010907884135

发证日期: 2023年06月01日

有效期至: 2026年05月21日

认证委托人名称 及注册地址	Bel Fuse Inc. 206 Van Vorst St, Jersey City, NJ 07302, 美国
产品生产者名称 及注册地址	Bel Fuse Inc. 206 Van Vorst St, Jersey City, NJ 07302, 美国
生产企业名称 及生产地址	宝威亚太电子(深圳)有限公司 深圳市光明新区公明办事处根玉路与南明路交汇处华宏信通工业园六栋
产品名称和系列、 规格、型号	电源 见附件(不带电线组件销售)(仅适用于海拔2000米及以下)
产品标准和 技术要求	GB 17625.1-2022(A类); GB 4943.1-2022; GB/T 9254.1-2021(A级)

上述产品符合 CNCA-C09-01:2014 认证规则的要求, 特发此证。

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2016年08月10日

经中国合格评定国家认可委员会认可 CNAS C001-P

可通过扫描下方二维码或登录国家认监委网站(www.cnca.gov.cn)查验证书信息



签发:

谢肇煦



中国质量认证中心



中国国家强制性产品认证证书

证书编号: 2016010907884135

第 1 页 共 1 页

本证书及附件应同时使用, 信息查验说明见证书页

纸号:

型号: PPC33 A022;

交流输入: 100-240V~, 12-5A, 50/60Hz;

或直流输入: 200-380Vdc, 7-4A

直流输出: V1:12Vdc, 70A, VSB: 3.3Vdc/5A or 5Vdc/3.3A

型号: PFE1500-12-054NA, SPABRCD-14G, PFE1500-12-054NAXXXX (XXXX= 0-9 的任

意数字或 A-Z 或 a-z 的任意字符或以上数字和字符组合, 代表不同的客户代码, 不影

响产品的安全和电磁兼容性能)

交流输入: 100-240V~, 12-7A, 50/60Hz;

直流输出: V1:12Vdc, 75A Max., VSB: 3.3Vdc/5A or 5Vdc/3.3A

型号: PFE1500-12NAS412

直流输入: 200-350Vdc, 10-5A

交流输入: 100-240V~, 12-7A, 50/60Hz;

直流输出: V1:12Vdc, 75A Max., VSB:12.0Vdc/3A

型号: PFE1500-12-054NAH, PFE1500-12-054NAHXXXX (XXXX=0-9 的任意数字或 A-Z 或

a-z 的任意字符或以上数字和字符组合, 代表不同的客户代码, 不影响产品的安

全和电磁兼容性能)

交流输入: 100-240V~, 12-7A, 50/60Hz;

直流输出: V1:12Vdc, 91A Max., VSB: 3.3Vdc/5A or 5Vdc/3.3A

型号: PFE1500-12NAHS412

交流输入: 100-240V~, 12-7A, 50/60Hz;

直流输入: 200-380Vdc, 10-5A

直流输出: V1:12Vdc, 91A Max., VSB: 12.0Vdc/3A

型号: SPABRCD-16

直流输入: 200-380Vdc, 10-5A

直流输出: V1:12Vdc, 91A Max., Vsb: 3.3Vdc/5A or 5Vdc/3.3A



中国质量认证中心



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2016010907884135

Valid from: Jun.01,2023

Valid until: May.21,2026

NAME AND REGISTERED ADDRESS OF THE APPLICANT Bel Fuse Inc.
206 Van Vorst St, Jersey City,NJ 07302 , USA

NAME AND REGISTERED ADDRESS OF THE MANUFACTURER Bel Fuse Inc.
206 Van Vorst St, Jersey City,NJ 07302 , USA

NAME AND LOCATION OF THE FACTORY BPS Asia Pacific Electronics (Shenzhen)Co.,Ltd.
The 3rd and 4th Floor,Bdg#6 of HHXT Industrial Park,Nanming Road,Gongming Town,Guangming District,Shenzhen

PRODUCT MODEL(S) AC-DC Converter , AC/DC-DC Converter, DC-DC Converter
See appendix (Sale without cord set)(Altitude up to 2000m)

STANDARDS AND TECHNICAL REQUIREMENTS GB 17625.1-2022(Class A);GB 4943.1-2022;GB/T 9254.1-2021(Class A)

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO. CNCA-C09-01:2014)

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Aug.10,2016

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE



CERTIFICATE NO. : 2016010907884135

page 1 of 1

paper:

This certificate and attachments shall be used at the same time, and the verification instructions can be found in the main certificate.

型号: PPC33 A022;

交流输入: 100-240V~, 12-5A, 50/60Hz;

或直流输入: 200-380Vdc, 7-4A

直流输出: V1:12Vdc, 70A, VSB: 3.3Vdc/5A or 5Vdc/3.3A

型号: PFE1500-12-054NA, SPABRCD-14G, PFE1500-12-054NAXXXX (XXXX= 0-9 的任意数字或 A-Z 或 a-z 的任意字符或以上数字和字符组合, 代表不同的客户代码, 不影响产品的安全和电磁兼容性能)

交流输入: 100-240V~, 12-7A, 50/60Hz;

直流输出: V1:12Vdc, 75A Max., VSB: 3.3Vdc/5A or 5Vdc/3.3A

型号: PFE1500-12NAS412

直流输入: 200-350Vdc, 10-5A

交流输入: 100-240V~, 12-7A, 50/60Hz;

直流输出: V1:12Vdc, 75A Max., VSB:12.0Vdc/3A

型号: PFE1500-12-054NAH, PFE1500-12-054NAHXXXX (XXXX=0-9 的任意数字或 A-Z 或 a-z 的任意字符或以上数字和字符组合, 代表不同的客户代码, 不影响产品的安全和电磁兼容性能)

交流输入: 100-240V~, 12-7A, 50/60Hz;

直流输出: V1:12Vdc, 91A Max., VSB: 3.3Vdc/5A or 5Vdc/3.3A

型号: PFE1500-12NAHS412

交流输入: 100-240V~, 12-7A, 50/60Hz;

直流输入: 200-380Vdc, 10-5A

直流输出: V1:12Vdc, 91A Max., VSB: 12.0Vdc/3A

型号: SPABRCD-16

直流输入: 200-380Vdc, 10-5A

直流输出: V1:12Vdc, 91A Max., Vsb: 3.3Vdc/5A or 5Vdc/3.3A



CHINA QUALITY CERTIFICATION CENTRE