



# Certificate of Compliance

**Certificate:** 70040688 (170351)

**Master Contract:** 170351

**Project:** 70040688

**Date Issued:** 2015-07-31

**Issued to:** **Bel Fuse Inc.**  
**206 Van Vorst St**  
**Jersey City, New Jersey 07302**  
**USA**

**Attention:** Editha S. Vergara

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.*



**Issued by:** Juan-Carlos Olivera,  
MSc.

## **PRODUCTS**

CLASS – 5311 11 - POWER SUPPLIES - Component Type (CSA 60950-1-07-2nd Ed)

CLASS – 5311 91 - POWER SUPPLIES - Component Type (UL 60950-1-2nd Ed) - Certified to U.S. Stds

For details related to rating, size, configuration, etc. reference should be made to the CSA Certification Record or the descriptive report.

Component type power supplies intended for use with Information Technology and Business Equipment, where the suitability of the combination is to be determined by CSA Group.



**Certificate:** 70040688

**Master Contract:** 170351

**Project:** 70040688

**Date Issued:** 2015-07-31

AC/DC Switching Power Supply, Model LPM409 Series; rated Input: 100-240 V ac, 8.5-3.5 A, 50-60 Hz; Output: maximum 700 W or Input: 200-240 V ac, 5.3-4.5 A, 50-60 Hz; Output: Maximum 900 W; specified as follows:

LPM    4        09    -    E    F    G    H    -    X  
           I        II        III                    IV                    V

I – Model Series: LPM

II – Number of Slots: 4

III – Maximum Output Power:

09 = 900 W

IV – Output Modules:

Module	Model Name	Nominal Output Voltage (V dc)	Voltage Range (V dc)	Maximum Output Current (A)	Maximum Output Power (W) *
E	LPM126-OUTA1-5	5	2.0 to 5.3	53	265
F	LPM126-OUTA1-12	12	5.2 to 15	22	265
G	LPM126-OUTA1-24	24	14 to 30	11	265
H	LPM126-OUTA1-36	36	29 to 44	7.4	265
J	LPM126-OUTA1-48	48	43 to 54	5.5	265
K	LPM109-OUTA1-10	10	1.5 to 15	6	90
L	LPM109-OUTA1-20	20	3 to 32	3	90
M	LPM118-OUTA2-10	10	2x 1.5 to 15	2x 6	2x 90
N	LPM118-OUTA2-20	20	2x 3 to 32	2 x 3	2x 90
0	-	Blank Panel Slot Cover			

Note: Any module may be placed on any slot location.

\*Maximum output power of modules are derated based on operating ambient and input voltage. See below for details:

- 1) Module E: LPM126-OUTA1-5  
 Maximum 225 W for input voltage from 85-150 V ac, 40°C ambient  
 Maximum 175 W for input voltage from 85-264 V ac, 50 to 70°C ambient
- 2) Module F, G, H: LPM126-OUTA1-12, LPM126-OUTA1-24, LPM126-OUTA1-36  
 Maximum 225 W for input voltage from 85-150 V ac, 50°C ambient  
 Maximum 175 W for input voltage from 85-264 V ac, 70°C ambient
- 3) Module K, L: LPM109-OUTA1-10, LPM109-OUTA1-20



**Certificate:** 70040688

**Project:** 70040688

**Master Contract:** 170351

**Date Issued:** 2015-07-31

Maximum 45 W for input voltage from 85-264 V ac, 70°C ambient

- 4) Module M, N; LPM109-OUTA2-10, LPM118-OUTA2-20  
Maximum 90 W for input voltage from 85-264 V ac, 70°C ambient

V – Optional Suffixes (denoting non-safety critical options)

### **APPLICABLE REQUIREMENTS**

- |   |  |
|---|--|
| CAN/CSA-C22.2 No 60950-1-07,<br>+Am.1:2011 +Am.2:2014 | – Information Technology Equipment - Safety - Part 1: General Requirements |
| UL 60950-1-2014                                       | – Information Technology Equipment - Safety - Part 1: General Requirements |

### **CONDITIONS OF ACCEPTABILITY**

1. The power supply is to be installed only by trained service personnel, according to manufacturer installation instructions.
2. Evaluated for use in Pollution Degree 2 Environment, for ambient temperature of 40°C, 50°C and 70°C.
3. Temperature tests shall be considered for specific installation conditions in the end system.
4. Evaluated as Class I (earthed equipment). Reliable connection to protective earth shall be provided in the end use installation.
5. Spacings were evaluated for an operating altitude of max 10,000 ft (3048 m), based on IEC-60664-1 altitude correction factor.
6. Evaluated for connection to AC power with a branch circuit protector rated max 20 A. If used on a branch circuit with higher rating, additional testing shall be considered.
7. The front bezel has been evaluated and found compliant with requirements for FIRE, MECHANICAL and ELECTRICAL enclosure. Overall enclosure suitability is to be determined in the end system.
8. Output circuits in all modules are SELV and at hazardous energy levels (240 VA).
9. The input connector is suitable for field wiring.



## *Supplement to Certificate of Compliance*

**Certificate:** 70040688 (170351)

**Master Contract:** 170351

*The products listed, including the latest revision described below,  
are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

---

<b>Project</b>	<b>Date</b>	<b>Description</b>
70040688	2015-07-31	AC/DC Switching Power Supply, Model LPM409 Series. (C/US) (transferred from 173688 - 2412039 and upgraded to include Am2).

Product AC-DC switching power supply

Applicant Bel Fuse Inc.  
206 Van Vorst St.  
Jersey City, NJ 07302  
USA

Manufacturer Bel Fuse Inc.  
206 Van Vorst St.  
Jersey City, NJ 07302  
USA

Factory  See page 2

Ratings Input: 100-240Vac, 8.5-3.5A, 50-60Hz or 200-240Vac, 5.3-4.5A, 50-60Hz

Trade mark   
a bel group

Model / Type Ref. LPM409 Series

Principal characteristics Output: 700W Maximum or 900 W Maximum  
 See next page(s)

A sample of the product was tested and found to be in conformity with OFF EN 60950-1:2006;A11;A1;A12;A2

Validity This certificate documents conformity with the standards shown, and also applies as license for use of Nemkos name and certification mark. The certificate and license is valid as long as the applicable conditions are complied with, and provided that any changes to the product are notified to Nemko for acceptance prior to implementation.  
New standards or amendments to the standards may imply that the product design must be updated and/or that re-testing and re-certification is necessary.

Additional information  See next page(s)

The abovementioned certified equipment complies with current regulatory requirements regarding electrical safety in Norway and other EU/EEA member states, as far as this can be checked. Compliance with requirements regarding building-in, protection against electric shock and Electromagnetic Compatibility (EMC) must be checked when the equipment is built-in a completed product or forms a part of a complete system.

Additional model(s)  See next page(s)

Date of issue 10-09-2015



Juan Z. Kleppenes  
Certification Department

Factories:

Avnet Technology Solutions  
6700 W MORELOS PL  
CHANDLER, AZ 85226  
USA

Bel Power Solutions, s.r.o.  
Areal ZTS 924  
01841 Dubnica nad Vahom  
Slovakia

Sonitrones S A De CV Arrow Electronics Inc  
Blvd Luis Donaldo Colosio #1179  
84048 Nogales  
Mexico

Master Electronics  
610 East 10th Street  
Oakland, CA 94606  
USA

Date of issue 10-09-2015



Juan Z. Kleppenes  
Certification Department

**Nemko AS**

Gaustadalléen 30, P.O. Box 73 Blindern, 0314 Oslo, Norway  
TEL +47 22 96 03 30 FAX +47 22 96 05 50 EMAIL info@nemko.com  
ENTERPRISE NUMBER NO974404532

**CB TEST CERTIFICATE CERTIFICAT D'ESSAI OC**Product  
Produit

AC-DC switching power supply

Name and address of the applicant  
Nom et adresse du demandeurBel Fuse Inc.  
206 Van Vorst St.  
Jersey City, NJ 07302  
USAName and address of the manufacturer  
Nom et adresse du fabricantBel Fuse Inc.  
206 Van Vorst St.  
Jersey City, NJ 07302  
USAName and address of the factory  
Nom et adresse de l'usineNote: When more than one factory, please report on page 2  
Note: Lorsque il y plus d'une usine, veuillez utiliser la deuxième page Additional information on page 2Ratings and principal characteristics  
Valeurs nominales et caractéristiques principales

Input: 100-240Vac, 8.5-3.5A, 50-60Hz or 200-240Vac, 5.3-4.5A, 50-60Hz

Trademark (if any)  
Marque de fabrique (si elle existe)Type of Manufacturer's Testing Laboratories used  
Type de programme du laboratoire d'essais constructeur

LPM409 Series

Model / Type Ref.  
Ref. De typeAdditional information (if necessary may also be reported on page 2)  
Les informations complémentaires (si nécessaire, peuvent être indiqués sur la deuxième page)

Output: 700W Maximum or 900 W Maximum

 Additional information on page 2A sample of the product was tested and found to be in conformity with  
Un échantillon de ce produit a été essayé et a été considéré conforme à la

IEC 60950-1(ed.2);am1;am2

As shown in the Test Report Ref. No. which forms part of this Certificate  
Comme indiqué dans le Rapport desais numéro de référence qui constitue partie de ce Certificat

291975

This CB Test Certificate is issued by the National Certification Body  
Ce Certificat desai OC est établi par l'Organisme **National de Certification**Gaustadalléen 30  
NO-0373 Oslo, Norway

Date: 10-09-2015

Signature: Juan Z. Kleppenes  
Certification Department

Avnet Technology Solutions  
6700 W MORELOS PL  
CHANDLER, AZ 85226  
USA

Sonitrones S A De CV Arrow Electronics Inc  
Blvd Luis Donaldo Colosio #1179  
84048 Nogales  
Mexico


Bel Power Solutions, s.r.o.  
Areal ZTS 924  
01841 Dubnica nad Vahom  
Slovakia



Master Electronics  
610 East 10th Street  
Oakland, CA 94606  
USA





<p><b>TEST REPORT</b></p> <p><b>IEC 60950-1</b></p> <p><b>Information technology equipment – Safety –</b></p> <p><b>Part 1: General requirements</b></p>	
<b>Report Number</b> .....	291975
<b>Date of issue</b> .....	04 September, 2015
<b>Total number of pages</b> .....	66
<b>Applicant's name</b> .....	Bel Fuse Inc.
<b>Address</b> .....	206 Van Vorst St., Jersey City, NJ 07302
<b>Test specification:</b>	
<b>Standard</b> .....	IEC 60950-1:2005 (Second Edition) + Am 1:2009 + Am 2:2013
<b>Test procedure</b> .....	CB-Scheme
<b>Non-standard test method</b> .....	N/A
<b>Test Report Form No.</b> .....	IEC60950_1F
<b>Test Report Form(s) Originator</b> .....	SGS Fimko Ltd
<b>Master TRF</b> .....	Dated 2014-02
<p><b>Copyright © 2014 IEC System of Conformity Assessment Schemes for Electrotechnical Equipment and Components (IECEE System). All rights reserved.</b></p> <p>This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.</p> <p><b>This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.</b></p>	
<b>General disclaimer:</b>	
<p>The test results presented in this report relate only to the object tested. This report shall not be reproduced, except in full, without the written approval of the Issuing CB Testing Laboratory. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report.</p>	

<b>Test item description</b> .....	: AC-DC switching power supply
<b>Trade Mark</b> .....	:  a bel group
<b>Manufacturer</b> .....	: Same as Applicant
<b>Model/Type reference</b> .....	: LPM409 Series (See General Product Information for exact model names)
<b>Ratings</b> .....	: Input: 100-240 Vac, 8.5-3.5 A, 50-60 Hz; Output: 700 W Maximum  or : Input: 200-240 Vac, 5.3-4.5 A, 50-60 Hz; Output: 900 W Maximum

Testing procedure and testing location:		
<b>CB Testing Laboratory:</b>	Nemko USA Inc.	
<b>Testing location/ address</b> .....	2210 Faraday Ave. Suite 150, Carlsbad, CA 92008, USA	
<b>Associated CB Testing Laboratory:</b>		
<b>Testing location/ address</b> .....		
<b>Tested by (name + signature)</b> .....	George Daverin	
<b>Approved by (name + signature)</b> .....	Jeff Busch	

**Report History:**

Original report

**List of Attachments** (including a total number of pages in each attachment):

Attachment 1: European Group Differences and National Deviations .....81 pages

Documented deviations contain individual national documents for several European countries that are included in the European Group Deviations. The European Group Difference: EN60950:2006/A11:2009/A1:2010/A12:2011/A2:2013 are considered "Normative". The individual national documents (Denmark, Finland, Germany, Ireland, Norway, Spain, Sweden, Switzerland and United Kingdom) are considered "informative" and included at the manufacturer's request.

Attachment 2: Miscellaneous Documentation, e.g. Photos, PWB Layout, Schematic etc. ....56 pages

(Not for publication – Engineering use only)

Summary of testing	
General	All comments relate to all models, unless specifically stated.
Power supply	The equipment is an enclosed, Class I switch mode power supply with universal AC input and multiple DC voltage outputs for building-in. This report covers multiple models and all comments / tests apply to all models unless otherwise indicated. Testing was conducted on various models as indicated.
1.1.2; The unit is intended to operate at an altitude of up to 3050 m.	This equipment is intended to be operated at an altitude of up to 3048 m, so the clearance is multiplied by the altitude correction factor (1.15), specified in table A.2 of IEC 60664-1 2 <sup>nd</sup> Edition:2007-04. Refer to Tables 2.10.3 and 2.10.4.
1.7.2; Safety instructions.	Instructions and equipment markings related to safety are to be provided in a language, which is acceptable in the country in which the equipment is to be sold. English language verified.
1.7.2.4; IT power distribution systems.	The equipment complies with the requirements for connection to the Norwegian IT power systems. The following information should be given (but is not required) in the installation instruction: "This product is also designed for IT power system with Phase to Phase voltage 230V."
2.7.4; Number and location of protective devices.	In Norway, IT power distribution system is used. Equipment with a single protective device is accepted in Norway. Other countries may have additional requirements.
2.7.6; Warning to service personnel.	After operation of the protective device, the equipment is still under voltage if it is connected to an IT-power system. A warning is required for service personnel. Norway does not require this warning.
5.2;Electric strength test	Increased test voltages for Basic insulation applied to the equipment based on measured working voltages.

<b>Summary of testing:</b>	
<b>Tests performed (name of test and test clause):</b> 1) Input Test ..... 1.6.2 2) Durability Test ..... 1.7.11 3) Energy Measurement (240 VA) ..... 2.1.1.5 3) Capacitance Discharge Test..... 2.1.1.7 4) SELV Reliability Test..... 2.2 5) Protective Bonding Test..... 2.6.3.4 6) Humidity Test ..... 2.9.2 7) Working Voltage Measurement ..... 2.10.2 8) Hazardous Voltage Measurement ..... 2.10.2 9) Mechanical and Stress Relief Test ..... 4.2 10) Heating Test..... 4.5.1 11) Touch Current Test..... 5.1 12) Electric Strength Test..... 5.2.2 13) Component Failure Test ..... 5.3 14) Abnormal Operation Test..... 5.3 15) PS Output Overload and Short Test ..... 5.3 16) Transformer Overload Test..... Annex C	<b>Testing location:</b> See page 2

<b>Summary of compliance with National Differences</b>
<b>List of countries addressed:</b> Austria (AT), Australia (AU), Canada (CA), China (CH), Denmark (DK), Finland (FI), Germany (DE), Ireland (IE), Israel (IS), Korea (KR), Norway (NO), Slovenia (SI), Spain (ES), Sweden (SE), Switzerland (CH), United Kingdom (GB), United States of America (US)
<input checked="" type="checkbox"/> The product fulfils the requirements of: EN 60950-1:2006 + A11:2009 + A1:2010 + A12:2011 + A2:2013

**Copy of marking plate:** The artwork below may be only a draft. The use of certification marks on a product must be authorized by the respective NCBS that own these marks.

<b>AC-DC Converter</b>		<b>LPM409-RRRR-YYYYY</b>			
INPUT: ~ 100 – 240V 8,5 – 3,5A 50-60Hz		DC OUTPUT: 700W			
~ 200 – 240V 5,3 – 4,5A 50-60Hz		DC OUTPUT: 900W			
<b>OUTPUTS:</b>	SLOT 1	SLOT 2	SLOT 3	SLOT 4	
C-XXXXX	 nnV/pppW	 nnV/pppW	 nnV/pppW	 nnV/pppW	
<b>POWER SOLUTIONS &amp; PROTECTION</b> <small>a bel group</small>				B zzzzzzzz U uuuuuu Rev. vv(v) Lxx Wyyww Made in mmm	

<b>Calibration</b>	All instruments used in the tests given in this test report are calibrated and traceable to national or international standards. Further information about traceability will be given on request.
<b>Measurement uncertainty</b>	Measurement uncertainties are calculated for all instruments and instrument set-ups given in this report. Calculations are based on the principles given in the standard EA-4/02 (Dec. 1999), IEC Guide 115:2007, Nemko routine L227 and other relevant internal Nemko-procedures. Further information about measurement uncertainties will be given on request.
<b>Evaluation of results</b>	If not explicitly stated otherwise in the standard, the test is passed if the measured value is equal to or below (above) the limit line, regardless of the measurement uncertainty. If the measured value is above (below) the limit line, the test is not passed - ref IEC Guide 115:2007, and Nemko routine L220. The instrumentation accuracy is within limits agreed by IECCE-CTL (ref. Nemko routine L227).

<b>Test item particulars:</b>	
Equipment mobility.....	<input type="checkbox"/> movable <input type="checkbox"/> hand-held <input type="checkbox"/> transportable <input type="checkbox"/> stationary <input checked="" type="checkbox"/> for building-in <input type="checkbox"/> direct plug-in
Connection to the mains .....	<input type="checkbox"/> pluggable equipment <input type="checkbox"/> type A <input type="checkbox"/> type B <input checked="" type="checkbox"/> permanent connection <input type="checkbox"/> detachable power supply cord <input type="checkbox"/> non-detachable power supply cord <input type="checkbox"/> not directly connected to the mains
Operating condition .....	<input checked="" type="checkbox"/> continuous <input type="checkbox"/> rated operating / resting time:
Access location .....	<input type="checkbox"/> operator accessible <input type="checkbox"/> restricted access location <input checked="" type="checkbox"/> Component (to be determined in the end system)
Over voltage category (OVC) .....	<input type="checkbox"/> OVC I <input checked="" type="checkbox"/> OVC II <input type="checkbox"/> OVC III <input type="checkbox"/> OVC IV <input type="checkbox"/> other:
Mains supply tolerance (%) or absolute mains supply values .....	90 to 264 Vac
Tested for IT power systems .....	<input checked="" type="checkbox"/> Yes (Norway only) <input type="checkbox"/> No
IT testing, phase-phase voltage (V) .....	230
Class of equipment .....	<input checked="" type="checkbox"/> Class I <input type="checkbox"/> Class II <input type="checkbox"/> Class III <input type="checkbox"/> Not classified
Considered current rating of protective device as part of the building installation (A) .....	16 A for Europe, 20 A for North America
Pollution degree (PD) .....	<input type="checkbox"/> PD 1 <input checked="" type="checkbox"/> PD 2 <input type="checkbox"/> PD 3
IP protection class .....	IPX0
Altitude during operation (m) .....	3048m
Altitude of test laboratory (m) .....	Mean sea level (MSL)
Mass of equipment (kg) .....	1.38Kg

<b>Possible test case verdicts:</b>	
- test case does not apply to the test object.....	N/A
- test object does meet the requirement.....	P (Pass)
- test object does not meet the requirement.....	F (Fail)

<b>Testing.....</b>	
Date of receipt of test item .....	July 2015
Date(s) of performance of tests .....	August 2015

**General remarks:**

The test results presented in this report relate only to the object tested.

This report shall not be reproduced, except in full, without the written approval of the Issuing testing laboratory.

"(see Enclosure #)" refers to additional information appended to the report.

"(see appended table)" refers to a table appended to the report.

Throughout this report a  comma /  point is used as the decimal separator.

**Manufacturer's Declaration per sub-clause 4.2.5 of IEC 60950-1:**

The application for obtaining a CB Test Certificate includes more than one factory location  **Yes**  
and a declaration from the Manufacturer stating that the sample(s) submitted for  
evaluation is (are) representative of the products from each factory has been provided...:  **Not applicable**

**When differences exist; they shall be identified in the General product information section.**

**Name and address of factory (ies) ..... :**

- |  |  |
|--|--|
| 1)<br>Bel Power Solutions s.r.o<br>ArealZTS Dubnica n.Vahom c.924<br>01841 Dubnica nad Vahom<br>SLOVAKIA | 3)<br>Master Electronics<br>610 East 10th Street<br>Oakland CA 94606<br>USA                            |
| 2)<br>Avnet Technology Solutions<br>6700 W Morelos Place<br>Chandler AZ 85226<br>USA                     | 4)<br>Arrow Electronics Inc.<br>Boulevard Luis Donaldo Colosio 1179<br>84048 Nogales, Sonora<br>MEXICO |

**General product information:**

This test report is based on a TUV SUD test report Ref. No. SI1300016164-000 with appended CB cert Ref. No. DE 3 -500638, evaluated to the requirements of IEC 60950-1:2005 2<sup>nd</sup> ed. + A1:2009 + A2:2013. This test report includes addition evaluation of the power supply to the requirements of IT power systems and an engineering evaluation of the Leakage at the output of the PSU.

For continuity, data from the original TUV report is included in this report, along with the additional evaluation referenced.

The subject equipment is a component type AC-DC switching power supply provided with metal enclosure, fan and input connector. The unit consists of mother board, EMI board, PFC board and six output module slots. Each module is provided with isolating transformer and output busbar terminals for output connection.





**Conditions of Acceptability:**

Model(s) require:

- 1) The power supply is to be installed only by trained service personnel, according to manufacturer installation instructions.
- 2) Evaluated as Class I (earthed equipment). The power supply shall be properly bonded to the main protective earthing terminal in the end system.
- 3) Temperature tests shall be considered for specific installation conditions in the end system.
- 4) The front bezel has been evaluated and found compliant with requirements for FIRE, MECHANICAL and ELECTRICAL enclosure. Overall enclosure suitability is to be determined in the end system.
- 5) All modules output circuits are SELV and at hazardous energy level.
- 6) The input connector is not acceptable for field wiring; only intended for connection to mating connectors of internal wiring inside the end system.
- 7) The equipment was tested on a listed 20 A branch circuit. If used on a branch circuit with a greater rating, additional testing shall be considered.
- 8) The component was submitted by the manufacturer for use in a maximum air ambient of 40°C or 50°C (depending on module designation and input ratings) at full load and 70°C at 50% load.
- 9) The power supplies have been evaluated for use in a Pollution Degree 2 environment.

**Abbreviations used in the report:**

- normal conditions .....	N.C.	- single fault conditions .....	S.F.C
- functional insulation .....	OP	- basic insulation .....	BI
- double insulation .....	DI	- supplementary insulation .....	SI
- between parts of opposite polarity .....	BOP	- reinforced insulation.....	RI

Indicate used abbreviations (if any): ..... None